

UL Evaluation Report

UL ER11812-07

Issued: January 31, 2019

Revised: July 22, 2019

Visit UL,LLC's [Product iQ™ database](#)
for status of Report.

UL Category Code: ULEX

CSI MasterFormat®

DIVISION: 07 00 00 - THERMAL AND MOISTURE PROTECTION

Sub-level 2: 07 20 00 - Thermal Protection

Sub-level 3: 07 21 00 - Thermal Insulation

Sub-level 4: 07 21 13 - Board Insulation

COMPANY:

**AFM CORPORATION
17645 JUNIPER PATH, SUITE 260
LAKEVILLE, MN 55044**

www.borafoam.com



1. SUBJECT:

BORA-FOAM® INSULATION BOARDS

2. SCOPE OF EVALUATION:

- 2018 *International Building Code*® (IBC)
- 2018 *International Residential Code*® (IRC)
- 2018 *International Energy Code*® (IECC)
- ICC-ES Acceptance Criteria for Foam Plastic Insulation (AC12), dated June 2015 (editorially revised May 2016)
- ICC-ES Acceptance Criteria for Termite Resistant Foam Plastic (AC239), dated October 2008 (editorially revised February 2014)
- ICC-ES Acceptance Criteria for Quality Documentation (AC10), dated June 2014

Bora-Foam was evaluated for the following properties

- Surface Burning Characteristics (ANSI/UL723, ASTM E84)
- Physical Properties (ASTM C578)
- Flammability Testing for Use in Attics and Crawl Spaces (AC12, App. A and B)
- Termite Resistance (ICC-ES AC239)

3. REFERENCED DOCUMENTS

- ICC-ES:
 - ICC-ES Acceptance Criteria for Foam Plastic Insulation (AC12), dated June 2015 (editorially revised May 2016)
 - ICC-ES Acceptance Criteria for Quality Documentation (AC10), dated June 2014
 - ICC-ES Acceptance Criteria for Termite Resistant Foam Plastic (AC239), dated October 2008 (editorially revised February 2014)
- ANSI/UL:
 - ANSI/UL723 (ASTM E84), Test for Surface Burning Characteristics of Building Materials
- ASTM:
 - ASTM C578, Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation
 - ASTM E2178, Standard Test Method for Air Permeance of Building Materials

4. USES

4.1 Bora-Foam Insulation Boards

Bora-Foam is used as nonstructural insulation on the interior or exterior of above grade or below grade walls. Installation shall be in accordance with Section 6 of this report.

The insulation may be used as an air barrier to limit air infiltration in accordance with IECC Section [C402.4.1.2.1](#) when installation is in accordance with Section 6.2, and may be used on walls in attics and crawl spaces when installation is in accordance with Section 6.2.1.

5. PRODUCT DESCRIPTION

5.1 General:

Bora-Foam Insulation Boards are molded, closed-cell expanded polystyrene having a flame spread index not exceeding 25 and a smoke developed index not exceeding 450 for thicknesses up to 5 inches when tested in accordance with UL723 (ASTM E84) as required by Section [2603.3](#) of the IBC or Section [R316.3](#) of the IRC, as applicable.

Bora-Foam Insulation Boards are treated for termite resistance in accordance with Section [2603.9](#), exception 2 of the IBC or Section [R318.4](#), exception 2 of the IRC.

Bora-Foam Insulation Boards are manufactured at a minimum density of 0.90 lbs/ft³ and comply with ASTM C578 designation Type I. See Table 1 for thermal resistance.

Table 1 – Thermal Resistance of Foam-Control Insulation Boards

PRODUCT	ASTM C578 Type	DENSITY, min., lb/ft ³	THERMAL RESISTANCE ¹ , min., °F-ft ² -h/Btu
Bora-Foam	I	0.90	3.6

¹Thermal resistance (R) values are based on tested values at 1-inch thickness and 75°F mean temperature and must be multiplied by the installed thickness for thicknesses greater than 1 inch.

6. INSTALLATION

6.1 General:

Bora-Foam Insulation Boards are installed in accordance with the manufacturer's published installation instructions and this evaluation report. The manufacturer's published installation instructions and this report must be strictly adhered to, and a copy of the instructions shall be available on the jobsite during installation.

6.2 Bora-Foam Insulation Boards:

Bora-Foam Insulation Boards must be attached to the structure in a manner that will hold the insulation securely in place. The insulation boards must not be used structurally to resist transverse, axial or shear loads.

The interior of the building must be separated from the Bora-Foam Insulation Boards with a thermal barrier as required by Section [2603.4](#) of the IBC or Section [R316.4](#) of the IRC, as applicable.

Bora-Foam Insulation Boards may be used as vapor retarders based on perm values described in Table 2, when required in accordance with the applicable sections of the IBC, IRC and IECC. Vapor retarders are classified as follows:

Class I: 0.1 perm or less

Class II: 0.1 <perm ≤ 1.0

Class III: 1.0 <perm ≤ 10 perm

Table 2 – Water Vapor Permeance of Bora-Foam

PRODUCT	ASTM C578 Type	DENSITY, min., lb/ft ³	PERMEANCE ¹ , max., perms
Bora-Foam	I	0.90	0.3

¹Water vapor permeance values are based on 1-inch thickness when tested in accordance with ASTM C578 and ASTM E96. Actual water vapor permeance values vary based on insulation thickness.

6.2.1 Bora-Foam Insulation Boards Used in Attics and Crawl Spaces:

Bora-Foam Insulation Boards may be used in attics and crawl spaces, without the ignition barrier listed in Section [2603.4.1.6](#) of the IBC or Sections [R316.5.3](#) and [R316.5.4](#) of the IRC, as follows:

1. Attic ventilation is provided when required Section [1203.2](#) of the IBC or Section [R806](#) of the IRC, as applicable.
2. Under-floor (crawl space) ventilation is provided when required by Section [1203.3](#) of the IBC, or Section [R408.1](#) or Section [R408.3](#) of the IRC, as applicable.
3. Combustion air is provided in accordance with IMC Section [701](#) (2015 IMC).
4. Insulation boards are limited to a maximum thickness of 4 inches (102 mm).

7. CONDITIONS OF USE

7.1 General:

Bora-Foam Insulation Boards described in this report comply with, or are suitable alternatives to what is specified in those codes listed in Section 2 of this report, subject to the following conditions. The Bora-Foam Insulation Boards must be produced, identified, and installed in accordance with the manufacturer's published installation instructions. If there is a conflict between this report and the manufacturer's instructions this report governs.

The use of Bora-Foam Insulation Boards are not restricted in areas where the probability of termite infestation is defined as "very heavy" in accordance with Section [2603.9](#) of the IBC or Section [R318.4](#) of the IRC, as applicable.

7.2 Bora-Foam Insulation Boards:

The Bora-Foam Insulation Boards must be separated from the building interior with a thermal barrier, such as ½ inch thick gypsum board, as required by Section [2603.4](#) of the IBC or Section [R316.4](#) of the IRC, as applicable.

For a listing of applicable UL Certifications for Bora-Foam Insulation Boards, see the Product iQ™ database for the following categories.

- See Product iQ™ database for Foamed Plastic, UL Classified for Surface Burning Characteristics in accordance with UL723 ([BRYX](#)).
- See Product iQ™ database for Polystyrene Thermal Insulation, Rigid Cellular, UL Classified in accordance with ASTM C578 ([QORW](#)).

7.3 Manufacturing Locations:

The products described herein is manufactured at locations under the UL, LLC Listing or Classification and Follow-Up Service Program, which includes audits in accordance with ICC-ES Acceptance Criteria for Quality Documentation, AC 10.

8. SUPPORTING EVIDENCE

8.1 Bora-Foam Insulation Boards:

8.1.1 Data in accordance with ICC-ES Acceptance Criteria for Foam Plastic Insulation (AC12), dated June 2012 (editorially revised August 2013).

8.1.2 Data in accordance with ICC-ES Acceptance Criteria for Termite Resistant Foam Plastics (AC239), dated October 2008 (editorially revised February 2014).

8.1.3 Documentation of quality system elements described in AC10.

9. IDENTIFICATION

The Bora-Foam Insulation Boards described in this evaluation report are identified by:

- a marking bearing the report holder's name
- the plant identification
- the product name
- the ASTM type designation
- the UL Classification Mark
- the evaluation report number UL ER11812-07

The validity of the evaluation report is contingent upon this identification appearing on the product or UL Classification Mark certificate. The product is manufactured for the sole distribution of Crawlspace Depot, LLC.

10. USE OF UL EVALUATION REPORT

10.1 The approval of building products, materials or systems is under the responsibility of the applicable authorities having jurisdiction.

10.2 UL Evaluation Reports shall not be used in any manner that implies an endorsement of the product, material or system by UL.

10.3 The status of this report, as well as a complete directory of UL Evaluation Reports may be found at UL.com via [the Product iQ™ database](#).

© 2019 UL LLC

This UL Evaluation Report is not an endorsement or recommendation for use of the subject and/or product described herein. This report is not the UL Listing or UL Classification Report that covers the subject product. The subject product's UL Listing or UL Classification is covered under a separate UL Report. UL disclaims all representations and warranties whether express or implied, with respect to this report and the subject or product described herein. Contents of this report may be based on data that has been generated by laboratories other than UL that are accredited as complying with ISO/IEC Standard 17025 by the International Accreditation Service (IAS) or by any other accreditation body that is a signatory to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA). The scope of the laboratory's accreditation shall include the specific type of testing covered in the test report. As the accuracy of any non-UL data is the responsibility of the accredited laboratory, UL does not accept responsibility for the accuracy of this data.

